


QUICK-START PROCEDURE

- 1.) Have a licensed electrician connect control panel to an appropriate power source as indicated on the CWS data plate.
- 2.) Flush the piping system with water. Do not allow debris to enter the CWS system.
- 3.) Verify glycol used is a 35% propylene glycol mixture.
- 4.) Confirm pump rotation if using 3 phase power.
- 5.) Turn door switch to the “ON” position.
- 6.) Be sure to send a completed copy of the “Warranty Start-up Checklist” to G&D Tech Support!

WARRANTY START-UP CHECKLIST

Jobsite:				Tech Company:
Chiller Model:				Technician:
Chiller Serial #:				Start-Up Date:
FOLLOWING START-UP OF CWS, PLEASE SEND A COPY OF COMPLETED FORM TO G&D TECH SUPPORT				
CWS CLEARANCE (Include photos for warranty)	FRONT:	BACK:	LEFT:	RIGHT:
CHILLER MOUNTING (Anchor required)				
GLYCOL MIXTURE %				
GLYCOL LEVEL (Reservoir % Full)				
PHASE/VOLTAGE				
VOLTAGE TO GROUND (Note: High Leg to L2)	L1:	L2:	L3:	
PUMP ROTATION				
GLYCOL PRESSURE (PSI)				
	PUMP #1	PUMP #2	PUMP #3	PUMP #4
MOTOR AMPS:	L1:	L1:	L1:	L1:
	L2:	L2:	L2:	L2:
	L3:	L3:	L3:	L3: